

**MODENA CENTRO PROVE s.r.l.**

Sede legale e Laboratori: 41123 Modena (Italy) - Via Sallustio, 78  
Tel. 059 822417 r.a. - Fax 0598635115 - e-mail : [info@modenacentroprove.it](mailto:info@modenacentroprove.it) - [www.modenacentroprove.com](http://www.modenacentroprove.com)  
C.C.I.A.A. Modena n. 228587 - Tribunale di Modena n° 2231 - C.F. e P. IVA n. 01592020364

MECCANICA

ECOLOGIA

CERAMICA

AUTOMOTIVE

Modena, 26/05/21

To **HARDSCAPE.COM**  
15132 Park of Commerce Blvd. Ste # 103  
Jupiter, FL 33478

Attn.

MATERIAL and/or SAMPLE to be tested	Denomination of the Sample	Client Reference – Your delivery	date
Porcelain tiles	Porcelain Tiles 40x80x2	Vs consegna	23/04/2021

Here attached, you will receive the Test Report of Serial No. **20213338**/n, which shows the results of tests required.

**MODENA CENTRO PROVE**

MODENA CENTRO PROVE  
  
Director  
Sant'Unione dr. Giuseppe



**MODENA CENTRO PROVE s.r.l.**

Sede legale e Laboratori: 41123 Modena (Italy) - Via Sallustio, 78  
Tel. 059822417 r.a. - Fax 059380281 - e-mail : [info@modenacentroprove.it](mailto:info@modenacentroprove.it) - [www.modenacentroprove.com](http://www.modenacentroprove.com)  
C.C.I.A.A. Modena n. 228587 - Tribunale di Modena n° 2231 - C.F. e P. IVA n. 01592020364

## TEST REPORT: 20213338/1

Modena, 26/05/21


<b>CUSTOMER</b>	<b>HARDSCAPE.COM - 15132 Park of Commerce Blvd. Ste # 103 Jupiter, FL 33478</b>
<b>MATERIAL and/o SAMPLE to be tested</b>	Porcelain tiles;
<b>Denomination</b>	Porcelain Tiles 40x80x2;
<b>Date of sample reception</b>	23/04/2021;
<b>Kind of test executed</b>	Determination of Water Absorption
<b>Referring standards</b>	ASTM C373-18
<b>Shifting from standards</b>	No one
<b>Equipment</b>	Scales cod. MCP A241 - Forced ventilation stove cod. C43
<b>Subcontracted phases</b>	No one
<b>Sampling made by</b>	Customer

*The test results showing in this Report are only referred to the sample taken by our staff or supplied by the Customer. He commits himself to reproduce integrally this document. Partial reproduction is forbidden.  
The times of retain of the samples was indicated in the offer related to the test report.*

Examiner

  
p.i. Bortolai Alberto

MODENA CENTRO PROVE

  
Ceramic Dept. Responsible  
P.I. De Pasquale Roberto

MODENA CENTRO PROVE

  
Director  
Sant'Unione dr. Giuseppe



**MODENA CENTRO PROVE s.r.l.**  
Sede legale e Laboratori: 41123 Modena (Italy) - Via Sallustio, 78  
Tel. 059822417 r.a. - Fax 059380281 - e-mail : [info@modenacentroprove.it](mailto:info@modenacentroprove.it) - [www.modenacentroprove.com](http://www.modenacentroprove.com)  
C.C.I.A.A. Modena n. 228587 - Tribunale di Modena n° 2231 - C.F. e P. IVA n. 01592020364

## DETERMINATION OF THE INTENSITY OF WATER ABSORPTION

Beginning date : 10/05/21

Analysis ending date : 11/05/21

**SAMPLE** : Ceramic tiles, marked « **Porcelain Tiles 40x80x2**

»

### RESULTS

Sample n°	Water Absorption (%)
1	0,08%
2	0,09%
3	0,11%
4	0,09%
5	0,12%
<b>Average value</b>	<b>0,10%</b>

Classification ANSI A137.1-2012:

P1

Examiner

  
p.i. Bortolai Alberto

MODENA CENTRO PROVE

  
Ceramic Dept. Responsible  
P.I. De Pasquale Roberto

MODENA CENTRO PROVE

  
Director  
Sant'Unione dr. Giuseppe



**MODENA CENTRO PROVE s.r.l.**

Sede legale e Laboratori: 41123 Modena (Italy) - Via Sallustio, 78  
Tel. 059822417 r.a. - Fax 059380281 - e-mail : [info@modenacentroprove.it](mailto:info@modenacentroprove.it) - [www.modenacentroprove.com](http://www.modenacentroprove.com)  
C.C.I.A.A. Modena n. 228587 - Tribunale di Modena n° 2231 - C.F. e P. IVA n. 01592020364

## TEST REPORT: 20213338/2

Modena, 26/05/21


<b>CUSTOMER</b>	<b>HARDSCAPE.COM - 15132 Park of Commerce Blvd. Ste # 103 Jupiter, FL 33478</b>
<b>MATERIAL and/o SAMPLE to be tested</b>	Porcelain tiles;
<b>Denomination</b>	Porcelain Tiles 40x80x2;
<b>Date of sample reception</b>	23/04/2021;
<b>Kind of test executed</b>	Determination of Breaking Strength
<b>Referring standards</b>	ASTM C648-20
<b>Shifting from standards</b>	None
<b>Equipment</b>	Flexural test machine cod. MCP C93
<b>Subcontracted phases</b>	None
<b>Sampling made by</b>	Customer

*The test results showing in this Report are only referred to the sample taken by our staff or supplied by the Customer. He commits himself to reproduce integrally this document. Partial reproduction is forbidden.  
The times of retain of the samples was indicated in the offer related to the test report.*


Examiner

  
p.i. Bortolai Alberto

MODENA CENTRO PROVE

  
Ceramic Dept. Responsible  
P.I. De Pasquale Roberto

MODENA CENTRO PROVE

  
Director  
Sant'Unione dr. Giuseppe



## DETERMINATION OF BREAKING STRENGTH

Beginning date : 14/05/2021

Analysis ending date : 14/05/2021

**SAMPLE** : Ceramic tiles, marked « **Porcelain Tiles 40x80x2** »

The method consists of supporting the tile on the ends of three cylindrical rods arranged in an equilateral triangle and applying force at a definite rate to the centre of the triangular support, until the specimen breaks; on the center of the floor tiles it comes applied a force, through an appropriate system, that it increases with one defined speed, until the breach of the piece.

- Length of the sides of the triangular support used in testing : 76.2 mm

## RESULTS

Sample	Breaking Load (lbf)
1	3211
2	3204
3	3139
4	3266
5	3210
6	3144
7	3270
8	3299
9	3213
10	3246
<b>Average</b>	<b>3220</b>

## REQUIREMENTS

( Norm ANSI A 137.1)

Average breaking strength :  $\geq 250$  lbf

Examiner

p.i. Bortolai Alberto

MODENA CENTRO PROVE

Ceramic Dept. Responsible  
P.I. De Pasquale Roberto

MODENA CENTRO PROVE

Director  
Sant'Unione dr. Giuseppe



**MODENA CENTRO PROVE s.r.l.**  
Sede legale e Laboratori: 41123 Modena (Italy) - Via Sallustio, 78  
Tel. 059 822417 r.a. - Fax 059380281 - e-mail : [info@modenacentroprove.it](mailto:info@modenacentroprove.it) -  
[www.modenacentroprove.com](http://www.modenacentroprove.com)  
C.C.I.A.A. Modena n. 228587 - Tribunale di Modena n° 2231 C.F. e P. IVA n. 01592020364



LAB N°1018L

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC

Signatory of EA, IAF and ILAC Mutual Recognition Agreements

## TEST REPORT: 20213338/3

Modena, 26/05/21

<b>CUSTOMER</b>	<b>HARDSCAPE.COM - 15132 Park of Commerce Blvd. Ste # 103 Jupiter, FL 33478</b>
<b>MATERIAL and/o SAMPLE to be tested</b>	Porcelain tiles;
<b>Denomination</b>	Porcelain Tiles 40x80x2;
<b>Date of sample reception</b>	23/04/2021;
<b>Date of sample acceptance</b>	23/04/2021;
<b>Kind of test executed</b>	Determination of Dynamic Coefficient of Friction (DCOF)
<b>Referring standards</b>	ANSI A326.3:2017
<b>Shifting from standards</b>	No one
<b>Equipment</b>	Tribometer BOT3000E cod. MCP C143
<b>Subcontracted phases</b>	No one
<b>Sampling made by</b>	Customer

*The test results reported in this Test Report refer only to the sample sampled by our staff and / or given by the Customer as received.*

*The sample identification data were provided by the customer. Further additional information provided by the Customer will be reported in the Test Report in blue color. If the information provided by the customer influences the validity of the results, MCP declines all responsibility.*

*Any changes / additions made to the Test Report after its first issue will be identified by underlining the text.*


*The Customer undertakes to reproduce this document in its entirety. Any form of partial reproduction is prohibited.*

*The storage times of the samples are indicated on the offer or contract to which this Test Report refers.*


Examiner

  
p.i. Bortolai Alberto

MODENA CENTRO PROVE

  
Ceramic Dept. Responsible  
P.I. De Pasquale Roberto

MODENA CENTRO PROVE

  
Director  
Sant'Unione dr. Giuseppe



## DETERMINATION OF DYNAMIC COEFFICIENT OF FRICTION

Beginning date : 11/05/2021

Analysis ending date : 11/05/2021

**SAMPLE** : Ceramic tiles, marked « **Porcelain Tiles 40x80x2** »

» The test has been carried out using the instrument BOT 3000, tribometer of the coefficient of dynamic friction (DCOF) between a sliding SBR sensor and the surface of test.

### WET OPERATING CONDITION

Wet the path that the sensor will follow with 0,05% SLS (*Sodium-Lauryl Sulfate*) water.

### SAMPLE CLEANING

The sample has been clean with: RENOVATOR 120

### SENSOR VERIFICATION

Values of DCOF on standard tile before testing test specimens	<b>0.29</b>
Values of DCOF on standard tile after testing test specimens	<b>0.30</b>

### RESULTS

Test Condition	Measure 1	Measure 2	Measure 3	Measure 4	Average
Wet DCOF - tile 1	0.84	0.84	0.85	0.83	<b>0.84</b>
Wet DCOF - tile 2	0.84	0.85	0.83	0.83	<b>0.84</b>
Wet DCOF - tile 3	0.83	0.85	0.85	0.84	<b>0.84</b>

### REFERENCE VALUES

ANSI A137.1:2017 prescribe a minimum threshold of 0,42 for level interior spaces expected to be walked upon when wet.

Examiner

p.i. Bortolai Alberto

MODENA CENTRO PROVE  
Ceramic Dept. Responsible  
P.I. De Pasquale Roberto

MODENA CENTRO PROVE

Director  
Sant'Unione dr. Giuseppe

**MODENA CENTRO PROVE s.r.l.**

Sede legale e Laboratori: 41123 Modena (Italy) - Via Sallustio, 78  
Tel. 059822417 r.a. - Fax 059380281 - e-mail : [info@modenacentroprove.it](mailto:info@modenacentroprove.it) - [www.modenacentroprove.com](http://www.modenacentroprove.com)  
C.C.I.A.A. Modena n. 228587 - Tribunale di Modena n° 2231 - C.F. e P. IVA n. 01592020364

**TEST REPORT: 20213338/4**

Modena, 26/05/21

<b>CUSTOMER</b>	<b>HARDSCAPE.COM - 15132 Park of Commerce Blvd. Ste # 103 Jupiter, FL 33478</b>
<b>MATERIAL and/o SAMPLE to be tested</b>	Porcelain tiles;
<b>Denomination</b>	Porcelain Tiles 40x80x2;
<b>Date of sample reception</b>	23/04/2021;
<b>Kind of test executed</b>	Determination of the Resistance to Frost/Defrost Cycles
<b>Referring standards</b>	ASTM C1026-13(2018)
<b>Shifting from standards</b>	None
<b>Equipment</b>	Cold Room cod. MCP C133
<b>Subcontracted phases</b>	None
<b>Sampling made by</b>	Customer

*The test results showing in this Report are only referred to the sample taken by our staff or supplied by the Customer. He commits himself to reproduce integrally this document. Partial reproduction is forbidden.  
The times of retain of the samples was indicated in the offer related to the test report.*

**Examiner**

p.i. Bortolai Alberto

MODENA CENTRO PROVE

Ceramic Dept. Responsible  
P.I. De Pasquale Roberto

MODENA CENTRO PROVE

Director  
Sant'Unione dr. Giuseppe





**MODENA CENTRO PROVE s.r.l.**  
Sede legale e Laboratori: 41123 Modena (Italy) - Via Sallustio, 78  
Tel. 059822417 r.a. - Fax 059380281 - e-mail : [info@modenacentroprove.it](mailto:info@modenacentroprove.it) - [www.modenacentroprove.com](http://www.modenacentroprove.com)  
C.C.I.A.A. Modena n. 228587 - Tribunale di Modena n° 2231 - C.F. e P. IVA n. 01592020364

## DETERMINATION OF THE RESISTANCE TO FROST/DEFROST CYCLES

Beginning date : 23/04/2021

Analysis ending date : 24/05/2021

**SAMPLE** : Ceramic tiles, marked « **Porcelain Tiles 40x80x2** »

The test was performed by immersing 10 tiles in water for 24 hours and subsequently subjecting them to 5 hours at the boiling temperature, and additional 24 hours immersed in water. After this first phase, the tiles are subjected 300 times to freeze / thaw cycles from 0 ° F and 55 ° F, after 5 cycles, the specimens were removed and observed for surface defects.

### RESULTS

Water absorption after 24 h (%): < 0,1%  
Water absorption after 5h and 24h in boiling water (%): 0,1%  
Water absorption after 300 cycles:: 0,1%

Examiner

  
p.i. Bortolai Alberto

MODENA CENTRO PROVE

  
Ceramic Dept. Responsible  
P.I. De Pasquale Roberto

MODENA CENTRO PROVE

  
Director  
Sant'Unione dr. Giuseppe