

PRI Construction Materials Technologies LLC

6412 Badger Drive Tampa, FL 33610 813.621.5777 https://www.pri-group.com/

Laboratory Test Report

Report for: Aida Ricetti

Hardscape.com

15132 Park of Commerce Blvd. Ste # 103

Jupiter, FL 33487

Product Name(s):

Project No.:

2275T0003.6

Dates Tested:

Sep. 14, 2021

Test Methods:

ASTM C1371
ASTM C1549

ASTM C1549 ASTM E1980

Results Summary:

<u>Product</u> <u>SRI, Medium-Wind</u>

Bluestone Dark 31

Purpose: Determine the solar reflectance, thermal emittance, and solar reflectance index value(s)

of the tested product(s).

Test Methods: The test methods used included ASTM C1549-16: Standard Test Method for

Determination of Solar Reflectance Near Ambient Temperature Using a Portable Reflectometer, Procedure B and ASTM C1371-15: Standard Test Method for Determination of Emittance of Materials Near Room Temperature Using Portable Emissometers. Thermal emittance measurement for samples was modified in accordance with Devices and Services Company's Tech Note 04-1. Both of these methods are Energy Star, Leadership in Energy and Environmental Design (LEED), and Cool Roof Rating Council

(CRRC) approved methods for determining radiative properties.

The solar reflectance index (SRI) was calculated in compliance with ASTM E1980-11: Standard Practice for Calculating Solar Reflectance Index of Horizontal and Low-Sloped

Opaque Surfaces.

Sampling: The following materials were received by PRI.

 Product
 Source
 Date
 Sampling

 Bluestone Dark
 Tampa, FL
 Sep. 13, 2021
 Hardscape.com

2275T0003.6

The test results, opinions, or interpretations are based on the material supplied by the client. This report is for the exclusive use of stated client. No reproduction or facsimile in any form can be made without the client's permission. This report shall not be reproduced except in full without the written approval of this laboratory. PRI Construction Materials Technologies LLC assumes no responsibility nor makes a performance or warranty statement for this material or products and processes containing this material in connection with this report.

Hardscape.com
ASTM C1549 for Reflectance, ASTM C1371 for Emittance, and ASTM E1980 for Solar Reflectance Index (SRI)
Client provided sample(s)
Page 2 of 2

Results: All measurements were recorded at 73.4±1.8°F & 50±5%RH

ASTM E 1980

	Product	Solar Reflectance		Thermal Emittance		SRI		
		ASTM C1549 ¹		ASTM C1371 ²		ASTM E1980 ³		
		Avg.	Std.Dev.	Avg.	Std.Dev.	Low-Wind	Med-Wind	High-Wind
	Bluestone Dark - 16" x 32" x 1-1/8"	0.295	0.010	0.90	0.00	31	31	32

Note(s):

- 1- Reflectance measurements were conducted using a Devices and Services SSR-ER Version 6.4 Reflectometer operated in v5 emulation mode and calibrated with Devices and Services Reference Tile # D-18.
- 2- Emittance measurements were conducted using a Devices and Services Emissometer Model AE calibrated with Devices and Services Reference Standards: High Emittance: 0.86 and Low Emittance: 0.06. Thermal emittance measurement for sample was modified in accordance with Devices and Services Company's Tech Note 04-1.
- 3- SRI calculations per ASTM E 1980 Approach II utilize the following assumptions: Low-Wind h_c = 5 W/m²·K, Medium-Wind h_c = 12 W/m²·K, and High-Wind h_c = 30 W/m²·K.

Statement of Attestation: The Solar Reflectance Index of these samples was calculated in accordance with ASTM

E 1980: Standard Practice for Calculating Solar Reflectance Index of Horizontal and

Low-Sloped Opaque Surfaces. The laboratory test results presented in this report are
representative of the materials supplied.

Signed:

Brent Barbeau

Manager

Date:

Original

Sep. 22, 2021

2

Report Issue History:

Issue # Date Pages Revision Description (if applicable)

Sep. 22, 2021

END OF REPORT

NA

2275T0003.6

The test results, opinions, or interpretations are based on the material supplied by the client. This report is for the exclusive use of stated client. No reproduction or facsimile in any form can be made without the client's permission. This report shall not be reproduced except in full without the written approval of this laboratory. PRI Construction Materials Technologies LLC assumes no responsibility nor makes a performance or warranty statement for this material or products and processes containing this material in connection with this report.